

Repair Request #8157

ID	#8157
Kind	Maintenance
Campus	Fort
Requester	Emily Guerrero
Description	It has been raining heavily today, and we have noticed that the playground is flooding and water is seeping into the Nido II classroom, particularly along the corner near the playground. We have been cleaning and drying the area as needed, but the water continues to come in when it rains.
Priority	Urgent
Due	2026-10-02
Target Date	
Remarks	[2026-10-06 14:25:09] AUTHORIZED and ASSIGNED to Miltito by arturo: As part of the releveled of the playground, the angle of the nido2 door will be corrected to prevent accumulation of water in the door. [2026-10-16 14:02:50] Completed order moved to Archived by arturo through Approval Center bulk archive.
IP	76.108.236.103
Reviewed	Yes
Reviewed By	System — Direct to Authorization
Reviewed At	2026-10-01 10:35:36
Authorized By	arturo
Authorized At	2026-10-06 14:25:09
Denied By	
Denied At	
Denial Reason	
Reopened By	
Reopened At	
Reopen Note	
Started	2026-10-13 12:32:02


Status	Archived
Assigned To	Miltito
Submitted At	2026-10-01 10:35:36
Updated At	2026-10-16 14:02:50
Archived At	2026-10-16 14:02:50

Original Photos

Original Photo 1



Original Photo 2



Completion Photos

No completion photos attached.