

Repair Request #8181

ID	#8181
Kind	Repair
Campus	WPB
Requester	Aliya
Description	The Ac vent is dripping water in the office.
Priority	Urgent
Due	2026-10-06
Target Date	
Remarks	[2026-10-06 14:29:00] AUTHORIZED and ASSIGNED to Duvan by arturo: Duvan, please check the drain of the HVAC at the office. Please clean it and confirm is correctly pulling out the humidity water. [2026-10-08 22:02:43] Moved to Archived by arturo through Admin Bulk Status Update.
IP	107.219.75.93
Reviewed	Yes
Reviewed By	System — Direct to Authorization
Reviewed At	2026-10-05 10:18:24
Authorized By	arturo
Authorized At	2026-10-06 14:29:00
Denied By	
Denied At	
Denial Reason	
Reopened By	
Reopened At	
Reopen Note	
Started	2026-10-08 20:18:37
Status	Archived
Assigned To	Duvan


Submitted At	2026-10-05 10:18:24
Updated At	2026-10-08 22:02:43
Archived At	2026-10-08 22:02:43

Original Photos

Original Photo 1



Original Photo 2



Original Photo 3



Completion Photos

Completion Photo 1

